



UPDATE PEKERJAAN PENGADAAN PEMBARUAN FSS RUANG DATA CENTER & RUANG PAC PPA TK LT 5

NO	LOKASI	DISKRIPSI	KETERANGAN
1	RUANG DATA CENTER	a. instalasi Piping Fss Nozzle : - atas plafon - under raised floor - pengecatan ulang pipa fss b. instalasi Kabeling System Fss : - smoke detector atas plafon - smoke detector under raised floor - FAJB (fire alarm junction box) - gass discharge lamp - horn strobe - evacuate lamp - bell alarm - abort switch - manual release	Close
2	RUANG PAC	a. instalasi Piping Fss Nozzle : - atas plafon - under raised floor - pengecatan ulang pipa fss b. instalasi Kabeling System Fss : - smoke detector atas plafon - smoke detector under raised floor - FAJB (fire alarm junction box) - gass discharge lamp - horn strobe - evacuate lamp - bell alarm - abort switch - manual release	Close
3	RUANG TELCO	a. instalasi Kabeling System Fss : - smoke detector atas plafon - smoke detector under raised floor - FAJB (fire alarm junction box) - gass discharge lamp - horn strobe - evacuate lamp - bell alarm - abort switch - manual release	Close

PT. Platinum Network Indonesia

Jl. Wolter Monginsidi No. 88i, Kebayoran Baru, Jakarta Selatan 12170

Tel: (021) 722 4466, 722 4477, Fax: (021) 7221444, Email: info@platinum.net.id